

Borough of Rockaway



MUNICIPAL BUILDING • 1 EAST MAIN STREET • ROCKAWAY, NEW JERSEY 07866
www.rockawayborough.org • Telephone (973) 627-2000 • Fax (973) 627-8294

August 18, 2020

To: Colleen Reardon, Building Department
Fr: Tom Slockbower, Supt., Dept. of Public Works
Re: RPM
Subdivision
Block 73 Lot 65
West Main Street
Tax Map #13
Page 7 of 24

- No relocation of fire hydrant
- Upgrade water main from 6" to 8"
- Should have a loop water main from Mount Pleasant Avenue
- Upgrade water service from 3" to 6" D.T.P.
- Waste line to be 8" not 6"
- Water meter not listed should be in pit.
- We will need a study of the downstream flow for wastewater due to the impact of added flow and improvements

Need location of Recycle bin.