

# Borough of Rockaway



MUNICIPAL BUILDING • 1 EAST MAIN STREET • ROCKAWAY, NEW JERSEY 07866  
www.rockawayborough.org • Telephone (973) 627-2000 • Fax (973) 627-8294

August 18, 2020 WITH APPLICANT'S RESPONSES\  
AUGUST 30, 2020

To: Colleen Reardon, Building Department  
Fr: Tom Slockbower, Supt., Dept. of Public Works  
Re: RPM  
Subdivision  
Block 73 Lot 65  
West Main Street  
Tax Map #13  
Page 7 of 24

- No relocation of fire hydrant THE LOCATION FOR THE HYDRANT TO BE RELOCATED WILL BE SHOWN ON REVISED PLANS
- Upgrade water main from 6" to 8" WILL REVISE TO 8"
- Should have a loop water main from Mount Pleasant Avenue THIS IS NOT PRACTICAL OR FEASIBLE GIVEN THE TOPOGRAPHY AND THE FACT THE WATER LINE WOULD HAVE TO GO UNDER THE PROPOSED RETAINING WALL SYSTEM
- Upgrade water service from 3" to 6" D.T.P. WILL REVISE TO 6"
- Waste line to be 8" not 6" WILL REVISE TO 8"
- Water meter not listed should be in pit. WILL PROVIDE METER PIT
- We will need a study of the downstream flow for wastewater due to the impact of added flow and improvements PLEASE STUDY TO CONFIRM CAPACITY.

Need location of Recycle bin.